

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 2200-1622:0100

CATEGORY: 2200 -- CEILING SUSPENSION SYSTEMS/PANELS

LISTEE: EMPIRE WEST PLASTICSPO Box 511, 9720 Graton Road, Graton, CA 95444
Contact: Ed Davis (707) 823-1190 Fax (707) 823-8531
Email: Ed@empirewest.com

DESIGN: Model *Ceilume Polyvinyl chloride plastic single and double sheets to form 2' x 2' to 2' x 4' nominal ceiling panels. Type I, single sheet; Type II, nested or welded sheets; Type III and IV, nested or welded double sheets with a laminated top sheet; Type V, top and bottom sheet mechanically laminated to a flexible vinyl center sheet. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: Flame Spread; Type I: 20; Type II: 25; Type III: 35; Type IV: 20; Type V: 25
Smoke Developed; Type I: 150; Type II: 350; Type III: 400; Type IV: 350; Type V: 350

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: *Cartons imprinted "Ceilume The Smart Ceiling Tile", and bearing the UL File Number R-4036 label.

APPROVAL: Listed as a ceiling panel having a Class I or II rating.

NOTE: Formerly 2180-0174:001, 2200-0174:001

12-14-06 kv



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011**

Listing Expires **June 30, 2012**

Authorized By: **FRANCIS MATEO, Program Coordinator**
Fire Engineering Division