



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	2200-1622:0100
<b>CATEGORY:</b>	2200 - CEILING SUSPENSION SYSTEMS/PANELS
<b>LISTEE:</b>	EMPIRE WEST PLASTICS PO Box 511, Graton, CA, 95444 Contact: Larman, Rachel (707) 823-1190 (707) 823-8531 Email: rachel@empirewest.com
<b>DESIGN:</b>	Model *Ceilume Polyvinyl chloride plastic single and double sheets to form 2' x 2' to 2' x 4' nominal ceiling panels. Type I, single sheet; Type II, nested or welded sheets; Type III and IV, nested or welded double sheets with a laminated top sheet; Type V, top and bottom sheet mechanically laminated to a flexible vinyl center sheet. Refer to listee's data sheet for detailed product description and operational considerations.
<b>RATING:</b>	Flame Spread; Type I: 20; Type II: 25; Type III: 35; Type IV: 20; Type V: 25 Smoke Developed; Type I: 150; Type II: 350; Type III: 400; Type IV: 350; Type V: 350
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	*Cartons imprinted "Ceilume The Smart Ceiling Tile" , and bearing the UL File Number R-4036 label.
<b>APPROVAL:</b>	Listed as a ceiling panel having a Class I or II rating.
<b>NOTES:</b>	Formerly 2180-0174:001, 2200-0174:001

12-14-06 kv



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 04/04/2024**

**Listing Expires: 06/30/2025**

Authorized By: **David Castillo**, Program Coordinator  
Fire Engineering & Investigations Division